

Emission Test Certificate

Wednesday July 23rd, 2008

Supplier: J H Wilberforce Pty. Ltd

37-43 Clune Street Bayswater

Western Australia 6053

Sample Description: Polyrey Compact Laminate

Date Tested: July 2008

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<p style="text-align: center;">Specification</p> <p style="text-align: center;">Green Building Council of Australia</p>	<p style="text-align: center;">Compact Laminate</p>
<p>Office Interiors V1.1 IEQ-11 < 0.5 mg/m³ (7 days)</p>	<p style="text-align: center;"><0.05 mg/m²/hr (7 days)</p> <p>When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m³.</p>



Dr. Vyt Garnys
 PhD, BSc(Hons) AImm, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

Project CV080719